



# A Neutral Controller For Series Transformer Using For-Pin Inverter

THUPAKULA PRAVEENA

M.Tech Student, Dept of EEE

Vidya Jyothi Institute of Engineering & Technology  
Ongole, A.P, India

S.AVINASH KUMAR

Associate Professor, Dept of EEE

Vidya Jyothi Institute of Engineering & Technology  
Ongole, A.P, India

**Abstract:** The neutral current that could flow toward transformer neutral point is compensated using a four-leg current source inverter topology for shunt part. The series transformer neutral is going to be at virtual zero potential during all operating conditions. Within this simulation we take notice of the power quality problems for example unbalanced current and current, harmonics by connecting non straight line load to 3P4W system with Unified Power Quality conditioner. Within this paper presents a Style of a Unified Power Quality conditioner (UPQC) linked to three phase four wire system (3P4W). The MATLAB/Simulink based simulations are supplied the functionality from the UPQC. The neutral of series transformer utilized in the 4th wire for that 3P4W system. A brand new control strategy for example unit vector template can be used to create the series APF to balance the unbalanced current contained in the burden currents by expanding the idea of single phase P-Q theory. The P-Q theory requested balanced three phase system. And remain employed for each phase of unbalanced system individually.

**Keywords:** Power Quality (PQ); PSCAD/EMTDC; Unified Power-Quality Conditioner (UPQC); Voltage-Source Converter (VSC);

## I. INTRODUCTION

To meet up with PQ standard limits, it might be essential to include some kind of compensation. Modern solutions are available in the type of active rectification or active filtering. A shunt active power filter is appropriate for that suppression of negative load affect on the availability network, but should there be supply current imperfections, a set active power filter may be required to supply full compensation. Additionally, lightning bombings of transmission lines, switching of capacitor banks, as well as other network problems may also cause PQ problems, for example transients, current sag/swell, and interruption. However, a rise of sensitive loads involving digital electronics and sophisticated process controllers needs a pure sinusoidal supply current for correct load operation [1]. A unified power-quality conditioner (UPQC) may be the extension from the unified power-flow controller (UPFC) concept in the distribution level. It includes combined series and shunt converters for synchronized compensation of current and current imperfections inside a supply feeder. Once the power flows of two lines beginning in a single substation have to be controlled, an interline power flow controller (IPFC) may be used. An IPFC includes two series VSCs whose electricity capacitors are coupled. This enables active capacity to circulate between your VSCs. With this particular configuration, two lines could be controlled concurrently to optimize the network utilization. The easiest GUPFC includes three converters-one connected in shunt and yet another two in series with two transmission lines inside a substation. The fundamental GUPFC can control

total five power system quantities, like a bus current and independent active and reactive power flows of two lines [2]. The idea of GUPFC could be extended for additional lines if required. This idea could be extended to create multiconverter configurations for PQ improvement in adjacent feeders. The IUPQC includes one series and something shunts ripper tools. It's connected between two feeders to manage public transit current of among the feeders, while controlling the current across a sensitive load within the other feeder. Within this configuration, the current regulation within the feeders is conducted through the shunt-VSC. Within this paper, a brand new configuration of the UPQC known as the multiconverter unified power-quality conditioner (MC-UPQC) is presented. The machine is extended with the addition of a set-VSC within an adjacent feeder. The suggested topology can be used as synchronized compensation of current and current imperfections both in feeders by discussing power compensation abilities between two adjacent feeders which aren't connected.




Fig.1. Framework of the system

## II. PROPOSED SYSTEM

Two feeders linked to two different substations give you the loads L1 and L2. The MC-UPQC is linked to two buses BUS1 and BUS2 with voltages of and, correspondingly. The shunt area of the MC-UPQC can also be linked to load L1 having a current of. Supply voltages are denoted by even though load voltages are land. Finally, feeder currents are denoted by and cargo currents are land. Bus voltages and therefore are distorted and could be exposed to sag/swell. The burden L1 is really a nonlinear/sensitive load which requires a pure sinusoidal current for correct operation while its current is no sinusoidal and possesses harmonics [3]. The burden L2 is really a sensitive/critical load which requires a purely sinusoidal current and should be fully shielded from distortion, sag/swell, and interruption. These kinds of loads mainly include production industries and demanding providers, for example medical centers, airports, or broadcasting centers where current interruption can lead to severe economical losses or human damages. The interior structure from the MC-UPQC, It includes three VSCs (VSC1, VSC2, and VSC3) that are connected consecutive via a common electricity-link capacitor. Within the suggested configuration, VSC1 is connected in series with BUS1 and VSC2 is connected in parallel with load L1 in the finish of Feeder1. VSC3 is connected in series with BUS2 in the Feeder2 finish. Secondary (distribution) sides from the series-connected transformers are directly connected in series with BUS1 and BUS2, and also the secondary (distribution) side from the shunt-connected transformer is connected in parallel with load L1. The MC-UPQC includes two series VSCs and something shunt VSC that are controlled individually. The switching control technique for series VSCs and also the shunt VSC are selected to become sinusoidal pulse width-modulation (SPWM) current control and hysteresis current control, correspondingly. Switching losses make the electricity-link capacitor current to lower [4]. Other disturbances, like the sudden variation of load, also affect the electricity link. To be able to regulate the electricity-link capacitor current, a proportional-integral (PI) controller can be used. Based on control objectives from the MC-UPQC, the burden current ought to be stored sinusoidal having constant amplitude whether or not the bus current is disturbed. The ability rating from the MC-UPQC is a vital factor when it comes to cost. Before calculation from the power rating of every VSC within the MC UPQC structure, two types of a UPQC are examined and also the best model which necessitates the minimum power rating is recognized as. All current and current phases utilized in this are phase quantities in the fundamental frequency. There are two models for any UPQC-quadrature compensation (UPQC-Q)

and in phase compensation (UPQC-P). Within the quadrature compensation plan, the injected current through the series- VSC keeps a quadrature advance exposure to the availability current to ensure that no real power is consumed through the series VSC at steady condition. This can be a big benefit when UPQC mitigates sag conditions. The series VSC also shares the volt-ampere reactive (VAR) from the load combined with the shunt-VSC, lowering the power rating from the shunt-VSC. The ability-rating calculation for that MC-UPQC is transported out based on the straight line load in the fundamental frequency. The suggested MC-UPQC and its control schemes happen to be tested through extensive situation study simulations using PSCAD/ EMTDC. The simulation results reveal that the harmonic components and unbalance of BUS1 current are paid for by injecting the correct series current. Within this figure, the burden current is really a three-phase sinusoidal balance current with controlled amplitude. To judge the control system capacity for unbalanced current compensation, a brand new simulation is conducted. Within this new simulation, the BUS2 current and also the harmonic aspects of BUS1 current offer a similar experience. Within the suggested configuration, the sensitive/critical strain on Feeder2 is fully shielded from distortion, sag/swell, and interruption. In addition, the controlled current over the sensitive strain on Feeder1 provides several customers who're also shielded from distortion, sag/swell, and momentary interruption [5]. Therefore, the price of the MC-UPQC should be balanced against the price of interruption, according to reliability indices, like the customer average interruption duration index and customer average interruption frequency index.

## III. CONCLUSION

The concept could be theoretically extended to multibus/MultiFinder systems with the addition of more series VSCs. The brand new configuration is known as multiconverter unified power-quality conditioner (MC-UPQC). Within this paper, a brand new configuration for synchronized compensation of current and current in adjacent feeders continues to be suggested. The performance from the MC-UPQC is evaluated under various disturbance conditions which are proven the suggested MC-UPQC provides the benefits below: power transfer between two adjacent feeders for sag/swell and interruption compensation over a conventional UPQC, the suggested topology is capable of doing fully protecting critical and sensitive loads against distortions, sags/swell, and interruption in 2-feeder systems. Compensation for interruptions without resorting to battery power storage system and, consequently, without storage capacity limitation discussing power compensation

abilities between two adjacent feeders which aren't connected.

#### IV. REFERENCES

- [1] L. Gyugyi, C. D. Schauder, S. L. Williams, T. R. Rietman, D. R. Torjerson, and A. Edris, "The unified power flow controller: A new approach to power transmission control," IEEE Trans. Power Del., vol. 10, no. 2, pp. 1085–1097, Apr. 1995.
- [2] A. Ghosh and G. Ledwich, "A unified power quality conditioner (UPQC) for simultaneous voltage and current compensation," Elect. Power Syst. Res., pp. 55–63, 2001.
- [3] F. Z. Peng, "Application issues of active power filters," IEEE Ind. Appl. Mag., vol. 4, no. 5, pp. 21–30, Sep./Oct. 1998.
- [4] L. Gyugyi, K. K. Sen, and C. D. Schauder, "Interline power flow controller concept: A new approach to power flow management in transmission systems," IEEE Trans. Power Del., vol. 14, no. 3, pp. 1115–1123, Jul. 1999.
- [5] M. Hu and H. Chen, "Modeling and controlling of unified power quality compensator," in Proc. 5th Int. Conf. Advances in Power System Control, Operation and Management, Hong Kong, China, 2000, pp. 431–435.